



Ref. Certif. No.

SG PSB-EH-00040

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC electric vehicle charging station
Name and address of the applicant	Sichuan Wolun Electric Manufacturing Co.,Ltd 108 Tianyuan Street, Xinmin Town Da'an District 643010 Zigong City, Sichuan Province PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Sichuan Wolun Electric Manufacturing Co.,Ltd 108 Tianyuan Street, Xinmin Town, Da'an District, 643010 Zigong City, Sichuan Province, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	Sichuan Wolun Electric Manufacturing Co.,Ltd 108 Tianyuan Street, Xinmin Town, Da'an District, 643010 Zigong City, Sichuan Province, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	See page 2
Model/type Ref.	WLE002-AC7KW, WLE012-AC7KW, WLE022-AC7KW, WLE032-AC7KW, WLE042-AC7KW, WLE052-AC7KW, WLE062-AC7KW, WLE072-AC7KW, WLE082-AC7KW, WLE092-AC7KW, WLE102-AC7KW, WLE112-AC7KW, WLE002-AC11KW, WLE012-AC11KW, WLE022-AC11KW, WLE032-AC11KW, WLE042-AC11KW, WLE052-AC11KW, WLE062-AC11KW, WLE072-AC11KW, WLE082-AC11KW, WLE092-AC11KW, WLE102-AC11KW, WLE112-AC11KW, WLE002-AC22KW, WLE012-AC22KW, WLE022-AC22KW, WLE032-AC22KW, WLE042-AC22KW, WLE052-AC22KW, WLE062-AC22KW, WLE072-AC22KW, WLE082-AC22KW, WLE092-AC22KW, WLE102-AC22KW, WLE112-AC22KW
A sample of the product was tested and found to be in conformity with	IEC 61851-1:2017
as shown in the Test Report Ref. No. which forms part of this certificate	085-233120101-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 125485 0001 Rev. 00

Date, 2024-04-24

(Frank Zhu)



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)

wonunTM**ON & UP**[®]
New Power of Wolun**wonun**[®]**wolun**[®]
NEW ENERGY
沃轮电气

Ratings and principal characteristics

Rated voltage (V):	For AC11KW and AC22KW series: 3P+N+PE, 400Vac±10%, 50Hz. For AC7KW series: 1P+N+PE, 230Vac±10%, 50Hz.
Rated current (A):	For AC7KW and AC22KW series: 32A. For AC11KW series: 16A.
Output power (kW):	For AC22KW series: 22kW. For AC11KW series: 11kW. For AC7KW series: 7kW.
Protection class:	Class I
Overvoltage category:	III
Pollution degree:	3
Degree of protection:	IP64 (Vehicle connector IP55)
Operating temperature:	-30 to 50°C

Remark: Certified mechanical circuit breaker is external and should be installed upstream close the charging station by the authorized local agent, and they should be used in an environment with IP64.

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 125485 0001 Rev. 00

Date, 2024-04-24

(Frank Zhu)

