

330525 Velomitor XA Piezo-velocity Sensor

Datasheet

Bently Nevada Machinery Condition Monitoring

141633 Rev. M



Description

The Velomitor XA (eXtended Application) Sensor is a ruggedized version of Bently Nevada's 330500 Velomitor Sensor. Its 316L stainless steel case and unique, weatherproof connector and cable assembly permit mounting without a housing. The Velomitor XA Sensor cable assembly is suitable for use in moist environments, and the Velomitor XA Sensor design meets the requirements of IP-65 and NEMA 4X dust ratings when properly installed with a mating extension cable.



If you are measuring a machine housing to determine where to install transducers, consider what kinds of data you need to obtain. Most common machine malfunctions (imbalance, misalignment, and so forth) originate at the rotor and cause a change in rotor vibration. The location you select on the housing must accurately conduct rotor vibration to the transducer.

Install the transducer carefully. If you don't, the transducer may not accurately detect vibrations and can transmit invalid data. Bently Nevada provides engineering services to accurately measure machine housings and to install transducers.



Specifications

Parameters are specified from +20 to +30 °C (+68 to +86 °F) and 100 Hz unless otherwise indicated.



Operating the unit outside the specified limits may result in false readings or loss of machine monitoring.

Sensitivity	3.94mV/mm/s (100 mV/in/s) ±5%.
Frequency Response	4.5 to 2,000 Hz (270 to 120,000 cpm) ±3.0 dB, 6.0 to 1,000 Hz (360 to 60,000 cpm) ±0.9 dB.
Temperature Sensitivity	-14% to +7.5% typical over the operating temperature range.
Velocity Range	1270 mm/s (50 in/s) peak.
Transverse Sensitivity	Less than 5% of sensitivity.
Amplitude Linearity	±2% to 152 mm/s (6 in/s) peak.
Mounted Resonant Frequency	Greater than 12 kHz.
Broadband Noise Floor (4.5 Hz to 2 kHz)	0.004 mm/s (160 min/s) rms, nominal.
Power Requirements	DC Voltage: -22 to -30 V _{DC} Bias Current: 2.5 to 6.0 mA
Output Bias Voltage	-12 ± 3.0 V _{DC} , Over Temperature Referenced to Pin A
Dynamic Output Impedance	Less than 2400 Ω

Broadband Noise Floor	Less than 0.004 mm/s (160 μin/s)
Grounding	Case isolated
Maximum cable length	305 metres (1,000 feet) of cable, BN part number 02173007 with no degradation of signal.

Environmental Limits

Operating Temperature Range	-55 °C to +121 °C (-67°F to +250°F)
Shock Survivability	5000 g peak, maximum
Relative Humidity	To 100% non-submerged; case is hermetically-sealed.
Magnetic Field Susceptibility	<51 min/s/gauss (50 gauss, 50-60 Hz)
Operating Temperature Range	-55 °C to +121 °C (-67°F to +250°F)
Shock Survivability	5000 g peak, maximum
Relative Humidity	To 100% non-submerged; case is hermetically-sealed.
Magnetic Field Susceptibility	<51 min/s/gauss (50 gauss, 50-60 Hz)

Physical Description

Weight	156 g (5.5 oz), typical
Diameter	28 mm (1.1 in)
Height	73.1 mm (2.88 in)
Case Material	316L stainless steel
Connector	2-pin Mil-C-26482 hermetically-sealed, 316L stainless steel shell.

Mounting Torque	45 N-m (33 ft-lb) maximum
Polarity	Pin A goes positive with respect to pin B when the sensor case motion is toward the connector.
Cable Bend Radius	1.5-in minimum bend radius.



Operating the unit outside the specified limits may result in false readings or loss of machine monitoring.

Before installing and using this product, read the 330500, 330525, and 330530 Velomitor Sensors User Guide (document 100076).

Compliance and Certifications

FCC

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:

- This device may not cause harmful interference.
- This device must accept any interference received, including interference that may cause undesired operation.

EMC

EMC Directive 2014/30/EU

RoHS

RoHS Directive 2011/65/EU

Maritime

330400 and 330425 only

ABS 2009 Steel Vessels Rules

1-1-4/7.7,4-8-3/1.11.1,4-9-7/13

Hazardous Area Approvals



For the detailed listing of country and product specific approvals, refer to the *Approvals Quick Reference Guide* (108M1756) available from Bently.com.

CSA/NRTL/C

190501 (Agency Approval Options 01 through 04)





Intrinsically Safe	Ex ia IIC T4: Class I, Div 1, Groups A, B, C, D. Class II, Group E, F and G Class III AEx ia IIC T4:
--------------------	--

	Class I, Div 1, Groups A, B, C, D; Class II, Groups E, F, G Class III Install per drawing 167536 T4 @ $-40\text{ }^{\circ}\text{C} \leq T_a \leq +100\text{ }^{\circ}\text{C}$ ($-40\text{ }^{\circ}\text{F} \leq T_a \leq +212\text{ }^{\circ}\text{F}$)
Intrinsically Safe and Non-Incendive	Ex nL IIC T4 Class I, Division 2, Groups A, B, C and D AEx nA T4 Class I, Division 2, Groups A, B, C and D Install per drawing 167536 T4 @ $-40\text{ }^{\circ}\text{C} \leq T_a \leq +100\text{ }^{\circ}\text{C}$ ($-40\text{ }^{\circ}\text{F} \leq T_a \leq +212\text{ }^{\circ}\text{F}$)
330400, 330425	Ex ia IIC T4 AEx ia IIC T4 Class I, Div 1 Groups A, B, C and D Class II, Groups E, F, and G Class III T4 @ $-40\text{ }^{\circ}\text{C} \leq T_a \leq 100\text{ }^{\circ}\text{C}$ Install per dwg 167538
330500	Ex ia IIC T4 AEx ia IIC T4 Class I, Division 1, Groups A, B, C and D Class II, Groups E, F, G Class III Install per dwg 167537 T4 @ $-40\text{ }^{\circ}\text{C} \leq T_a \leq 100\text{ }^{\circ}\text{C}$ Ex nL IIC T4 AEx nA IIC T4 Class I, Div 2, Groups A, B, C, D Install per dwg 167537 T4 @ $-40\text{ }^{\circ}\text{C} \leq T_a \leq 100\text{ }^{\circ}\text{C}$
330525	Ex ia IIC T4 AEx ia IIC T4 Class I, Division 1, Groups A, B, C and D Class II, Groups E, F, G Class III

<p>T4 @ $-40^{\circ}\text{C} \leq T_a \leq 100^{\circ}\text{C}$</p> <p>Ex nL IIC T4 AEx nA IIC T4 Class I, Div 2, Groups A, B, C, D</p> <p>Install per dwg 167539 T4 @ $-40^{\circ}\text{C} \leq T_a \leq 100^{\circ}\text{C}$</p>			
		Pi= 0.84W	Pi= 1.26W
		Ci-10.8nF	
		Li= 0	

ATEX/IECEX

190501, 330400, 330425, 330500, 330525

<p>190501</p> <p>Entity Parameters</p>	<p> II 1 G Ex ia IIC T4 Ga</p> <p> II 3 D Ex na IIC T4 Gc Ex tc III T130°C Dc</p> <p>T4@ $T_a = -55^{\circ}\text{C}$ to 121°C</p>													
	<table border="1"> <thead> <tr> <th>Zone 0/1</th> <th>Zone 2</th> </tr> </thead> <tbody> <tr> <td>Ui= 30V</td> <td>Ui= 30V</td> </tr> <tr> <td>Ii= 200mA</td> <td>Ii= 200mA</td> </tr> <tr> <td>Pi= 0.75W</td> <td>Pi= 1.14W</td> </tr> <tr> <td>Ci-27.2nF</td> <td></td> </tr> <tr> <td>Li= 0</td> <td></td> </tr> </tbody> </table>	Zone 0/1	Zone 2	Ui= 30V	Ui= 30V	Ii= 200mA	Ii= 200mA	Pi= 0.75W	Pi= 1.14W	Ci-27.2nF		Li= 0		
	Zone 0/1	Zone 2												
	Ui= 30V	Ui= 30V												
	Ii= 200mA	Ii= 200mA												
	Pi= 0.75W	Pi= 1.14W												
	Ci-27.2nF													
	Li= 0													
<p>330400, 330425, 330500, 330525</p>	<p> II 1 G Ex ia IIC T4 Ga</p> <p> II 3 D Ex na IIC T4 Gc Ex tc III T130°C Dc</p> <p>T4@ $T_a = -55^{\circ}\text{C}$ to 121°C</p>													
<p>Entity Parameters</p>	<table border="1"> <thead> <tr> <th>Zone 0/1</th> <th>Zone 2</th> </tr> </thead> <tbody> <tr> <td>Ui= 28V</td> <td>Ui= 28V</td> </tr> <tr> <td>Ii= 150mA</td> <td>Ii= 150mA</td> </tr> </tbody> </table>	Zone 0/1	Zone 2	Ui= 28V	Ui= 28V	Ii= 150mA	Ii= 150mA							
Zone 0/1	Zone 2													
Ui= 28V	Ui= 28V													
Ii= 150mA	Ii= 150mA													

Hazardous Area Conditions of Safe Use

ATEX/IECEX

Zone 0/1:


Equipment must be connected to equipment, which meets the abovelisted entity parameters.

The cables type A or B (in compliance with EN 60079-25) must respect the cable parameters listed with the entity parameters.

Zone 2 :

The supply electrical parameters shall not exceed the values mentioned in the tables above.

Ordering Information

 For the detailed listing of country and product specific approvals, refer to the *Approvals Quick Reference Guide* (108M1756) available from Bently.com.

330525-AA

A: Agency Approval Option

0 0	None Required
0 1	CSA/NRTL/C
0 2	SIRA/CENELEC

106765-AA Interconnect Cable

A: Length (in meters)

Minimum length	1 meter (3.3 feet)
Maximum length	25 meters (82 feet)

Order in increments of 3 meters.

Terminal Housing

Terminal Housing for terminating Velomitor XA Sensor cable to bulk cable listed above. The Terminal Housing provides local connection of the Velomitor XA Sensor signal wires to the monitor field wiring. Each Terminal Housing can accommodate up to 2 Velomitor XA Sensor Cables.

106769-AA

A: Conduit Fitting Option

0 0	No fittings supplied
0 1	One ¼ NPT fitting
0 2	Two ¼ NPT fittings

Accessories

100076	330500/330525 Velomitor Sensor and Velomitor XA Sensor User Guide
02173007	Bulk cable; two-conductor twisted, shielded. 22 AWG cable without connectors or terminal lugs. Specify length in feet.
103537-01	Terminal Mounting Block. Provides simple field wiring connection and can be mounted inside any standard Proximitor Sensor housing. One terminal mounting block is needed for each Velomitor XA Sensor connection.
03839144	Splash-resistant boot cover for interconnect cable assembly. The boot is made from fluorosilicone elastomer. Boot color is blue.
03839142	Bottom clamp used to secure the boot to the Velomitor XA Sensor case.
03839143	Top clamp used to secure the boot to the interconnect cable assembly.