



<p><b>TEST REPORT</b>  <b>IEC 60598-2-1</b>  <b>Luminaires</b>  <b>Part 2: Particular requirements</b>  <b>Section 1: Fixed general purpose luminaires</b></p>	
Report Number .....	: 6172771.50
Date of issue.....	: 2023-11-20
Total number of pages .....	: 60 pages (including this page 1)
Name of Testing Laboratory preparing the Report .....	: DEKRA Testing and Certification (Shanghai) Ltd.
Applicant's name.....	: Hangzhou Holux Lighting Technology Co., Ltd
Address.....	: No.47 Xiangyuan Road, Hangzhou, Zhejiang, 310015, China
<b>Test specification:</b>	
Standard .....	: IEC 60598-2-1:2020 used in conjunction with IEC 60598-1:2020
Test procedure .....	: ENEC scheme
Non-standard test method .....	: N/A
TRF template used .....	: IECEE OD-2020-F1:2021, Ed.1.4
Test Report Form No.....	: IEC60598_2_11
Test Report Form(s) Originator....	: Intertek Semko AB
Master TRF.....	: Dated 2022-04-14
<p><b>Copyright © 2022 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b></p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p><b>This report is not valid as a Test Report unless signed by an approved Testing Laboratory and appended to a Test Certificate issued by an NCB in accordance with IECEE 02.</b></p>	
<b>General disclaimer:</b>	
<p>The test results presented in this report relate only to the object tested.  This report shall not be reproduced, except in full, without the written approval of the Issuing NCB. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	

<b>Test item description</b> ..... :	LED HIGH BAY
<b>Trade Mark(s)</b> ..... :	
<b>Manufacturer</b> ..... :	Hangzhou Holux Lighting Technology Co., Ltd No.47 Xiangyuan Road, Hangzhou, Zhejiang, 310015, China
<b>Model/Type reference</b> ..... :	HB series (for detail please refer to annex model list)
<b>Ratings</b> ..... :	120 - 277 V~ or 220 - 240 V~; 50/60 Hz; max 240 W; ta 50 °C; Class I; IP65; (for detail please refer to annex model list)